



أزيدك للمقاولات العامة
وأعمال الإلكتروميكانيكال
Azeidk for General Contracting & MEP Solutions

Title

Material Submittal for Fire
Extinguishers

Brand

Falcon Gold - Emarat



Falcon Gold

YOU ARE SAFE WITH US

C.R.4030244617

012 6880407/0581444606

info@azeidk.com

www.azeidk.com

المقر الرئيسي - جدة:

برج الصفا، مقابل عزيز مول، أعلى شركة عبداللطيف جميل، مبنى A، الدور الثالث، مكتب رقم ٣٤٠

الرياض:

حي الملز، شارع صلاح الدين، بجوار شركة زين، الدور الثاني، مكتب رقم ١٦



أزيدك للمقاولات العامة
وأعمال الإلكتروميكانيكال
Azeidk for General Contracting & MEP Solutions

Index

- **Technical Data Sheets (Catalogues).**
- **Saber Certificate.**
- **Previous Approvals.**
- **Authorization Letter.**
- **Azeidk Co. Documents.**



Falcon Gold

YOU ARE SAFE WITH US

C.R.4030244617

012 6880407/0581444606

info@azeidk.com

www.azeidk.com

المقر الرئيسي - جدة:

برج الصفا، مقابل عزيز مول، أعلى شركة عبداللطيف جميل، مبنى A، الدور الثالث، مكتب رقم ٣٤٠

الرياض:

حي الملز، شارع صلاح الدين، بجوار شركة زين، الدور الثاني، مكتب رقم ١٦.



أزيدك للمقاولات العامة
وأعمال الإلكتروميكانيكال
Azeidk for General Contracting & MEP Solutions

Technical Data Sheets (Catalogues).



Falcon Gold

YOU ARE SAFE WITH US

C.R.4030244617

012 6880407/0581444606

info@azeidk.com

www.azeidk.com

المقر الرئيسي - جدة:

برج الصفا، مقابل عزيز مول، أعلى شركة عبداللطيف جميل، مبنى A، الدور الثالث، مكتب رقم ٣٤٠

الرياض:

حي الملز، شارع صلاح الدين، بجوار شركة زين، الدور الثاني، مكتب رقم ١٦.



Falcon Gold
YOU ARE SAFE WITH US



Standard Portable Carbon Dioxide Fire Extinguishers

Description

CO₂ Fire Extinguishers are generally used for industrial fires.

Ideal agent for class B, C & E fires.

CO₂ is electrically non-conductive and therefore safe for fighting fires in electrically powered equipment.

CO₂ gas does not deteriorate with storage or freeze in container.

Purity of our CO₂ gas reaches 99.98%.

Valve is made from brass provided with safety release valve.

CO₂ extinguishers are made of seamless carbon steel materials to withstand high storage pressure.

Snow horn with built-in nozzle specially designed to fit our valve to give the most efficient fire suppression.

After use, CO₂ disperses without leaving any contamination or corrosive residue.

CO₂ is colourless gas which reduces the oxygen of the air around the fire.

Approved by UAE Civil Defence.

Manufactured according to International Standards.

Available in black and red colour.

Other capacity of cylinders can be supplied upon request.

Specification

Model	FCD2	FCD5L	FCD4.5	FCD5	FCD6
Capacity (Ltr)	2	2.25	4.5	5	6
Test Rating	13b	13b	34b	34b	34b
Discharge Time (Sec)	≥6	≥8	≥9	≥9	≥9
Discharge Range (M)	3	3	4	4	4
Empty Weight (Kg)	5.95	6.45	11.1	11.1	15.3
Gross Weight (Kg)	7.95	8.70	15.6	16.1	21.3
Discharge Nozzle	Horn		Horn & Hose		
Operating Pressure (Bar)	70 Bar				
Test Pressure (Bar)	250 Bar				
Temperature Range	-30°C +60°C				
Extinguishing Agent	CO2				
Cylinder Material	St52				
Valve	Brass Hot Stamping				
Painting	Electrostatic Polyester Epoxy Resin				
Class Of Fire	B, C & E				

reserves the right to make changes at anytime without prior notice in Datsheet Ref No : FXD 042 Date of Issue : 13/06/2018 Ref No : 00



Falcon Gold
YOU ARE SAFE WITH US



Standard Portable Dry Powder Fire Extinguishers

Description

Steel cylinder of high quality ST14 by means of deep drawing and painted with anti-corrosive polyester paint (powder coating).

ABC dry chemical powder is effective on class A,B, C & E fires and it is ideal for multi-risk fire.

Corrosion and impact resistant polyester finish.

Equipped with entire brass valve with pistol system.

Ready for instant use and simple to operate.

Approved by UAE Civil Defence and it is manufactured according to International Standards.

The valve is equipped with safety release pressure to avoid any bursting of cylinders during high temperature.

Do not use on fires involving carbon disulphate and flammable metal.

Available in Red and Blue colours.

Capacity of cylinder can be supplied upon request.

Specification

MODEL	FDP1	FDP2	FDP3	FDP4.5	FDP6	FDP9	FDP10	FDP12						
Capacity (Kg)	1	2	3	4.5	6	9	10	12						
Fire Rating	3A 13B	5A 21B	13A 34B	21A 89B	21A 144B	34A 144B	34A 144B	34A 144B						
Diameter (mm)	90	130	130	130	160	185	185	185						
Breadth Of Extg. (mm)	130	140	150	185	230	240	240	240						
Height Of Extg. (mm)	240	300	355	430	405	495	495	560						
Total Height (mm)	305	360	430	520	490	590	590	660						
Discharge Range (M)	5	5	8	8	8	8	8	8						
Discharge Time (Sec)	~ 6	~ 6	~ 9	~ 12	~ 15	~ 16	~ 18	~ 21						
Empty Weight (Kg)	0.7	1.2	1.25	2.1	2.5	3.55	3.55	3.98						
Gross Weight (Kg)	1.7	3.2	4.25	6.6	8.5	12.55	13.55	15.98						
Packing Final Volume (M³)	0.004	0.007	0.008	0.013	0.014	0.024	0.025	0.03						
Cylinder Wall Thk. (mm)	1.0	1.0	1.0	1.2	1.2	1.5	1.5	1.5						
Hose	No Hose		With Hose and Horn											
Class Of Fire	A B C & E													
Extinguishing Agent	Abe 70 % Dry Chemical Powder													
Operating Pressure (Bar)	15													
Test Pressure (Bar)	30													
Valve	Nickle Plated With Rigid Handle & Safety Valve Pin													
Bottom Base	Polyproprene Plastic With Rubber Mixture To Provide Strong And Flexible Combined Properties With UV Stabilizer.													
Rising Pipe	Plastic/aluminium													
Temperature Range	-30°C To +60°C													
Cylinder Material	Cold Rolled Steel													
Painting	Electrostatic Polyester Epoxy Resin													
Printing	Clear Attractive Screen Printing													
Mounting	Wall Mounting Using Bracket													



reserves the right to make changes at anytime without prior notice in Datsheet Ref No : FXD 041 Date of Issue : 13/06/2018 Ref No : 00



Falcon Gold
YOU ARE SAFE WITH US



Standard Portable Dry Powder Automatic Fire Extinguishers

Description

Steel cylinder of high quality St 14 by means of deep drawing and painted with anti-corrosive polyester paint (powder coating).

ABC dry chemical powder is effective on class A, B, C, & E fires and is ideal for multi-risk fires.

Corrosion and impact resistant polyester paint finish.

Operation with automatic sprinkler at temperature 68°C.

Approved by Civil Defence and manufactured according to BS EN 3.
Available in red color.

Specification

MODEL	FDPA4.5	FDPA5	FDPA6	FDPA9	FDPA12
Capacity(Kg)	4.5	5	6	6	12
Fire Rating	21A 89B	21A 89B	21A 144B	21A 144B	21A 144B
Diameter(Mm)	275	275	275	360	420
Height (Mm)	210	210	210	210	225
Discharge Range (Mtr)	8	8	9	9	9
Discharge Time (Sec)	12-14	12-14	18	18	21
Cylinder Wall Thickness (Mm)	1.8	1.8	2	2	2
Class Of Fire	A B C & E				
Extinguishing Agent	ABC 70% Dry Chemical Powder				
Operating Pressure (Bar)	15				
Test Pressure (Bar)	30				
Operating Temperature	68°C				
Cylinder Material	Cold Rolled Steel				
Printing	Clear Attractive Silk Screen Printing				
Mounting	Ceiling Mounting				
Expellant Agent	Nitrogen				



reserves the right to make changes at anytime without prior notice in Datsheet Ref No : FXD 041-5 Date of Issue : 13/06/2018 Ref No : 00



Falcon Gold
YOU ARE SAFE WITH US



Mobile Carbon Dioxide Fire Extinguishers

Description

CO2 Fire Extinguishers are generally used for industrial fires.

Ideal agent for class B, C & E fires.

CO2 is electrically non-conductive and therefore safe for fighting fires in electrically powered equipment.

CO2 gas does not deteriorate with storage or freeze in container.

Purity of our CO2 gas reaches 99.98%

Valve is made from brass provided with safety release valve.

CO2 extinguishers are made of seamless carbon steel materials to withstand high storage pressure.

Snow horn with built-in nozzle specially designed to fit our valve to give the most efficient fire suppression.

After use, CO2 disperses without leaving any contamination or corrosive residue.

CO2 is colourless gas which reduces the oxygen of the air around the fire.

Approved by UAE Civil Defence.

Manufactured according to International Standards.

Available in black and red colour.

Other capacity of cylinders can be supplied upon request.



Specification

Model	FCD10	FCD20	FCD30	FCD45	FCD60
Capacity (Kg)	10	20	30	45	60
Discharge Time (Sec)	22	35	70	75	80
Discharge Range (M)	3	3	4	4	4
Hose length (M)	3	5	5	5	5
Class Of Fire	B, C & E				
Operating Pressure (Bar)	70 Bar				
Test Pressure (Bar)	250 Bar				
Temperature Range	-20°C +60°C				
Material	St52				
Valve	Brass Hot Stamping				
Paint Finish	Electrostatic Polyester Epoxy Resin				

reserves the right to make changes at anytime without prior notice in Datsheet Ref No : FXD 042-4 Date of Issue : 13/06/2018 Ref No : 00



Falcon Gold

FG STANDARD FALCON GOLD-200 AUTOMATIC FIRE EXTINGUISHERS

HFC-227ea

CF₃ - CHF - CF₃

Heptafluoropropane

Description

- Steel cylinder of high quality ST14 by means of deep drawing and painted with anti-corrosive polyester paint (powder coating).
- FM-200 gas is effective on class A,B, C & E fires and it is ideal for multi-risk fire.
- Corrosion and impact resistant polyester finish.
- Equipped with brass automatic sprinkler valve.
- Ready for instant use and simple to operate.
- Approved by UAE Civil Defence and it is manufactured according to International Standards.
- The valve is equipped with safety release pressure to avoid any bursting of cylinders during high temperature.
- Do not use on fires involving carbon disulphate and flammable metal.
- Available in white colour.
- Size capacity of cylinder can be supplied upon request.



Wood, Rubber,
Paper, Textiles



Petrol, Oil, Greases,
other alcohol



Propane, Butane, methane,
Acetylene, Town gas



Fires on electrical
equipment

Specifications

DESCRIPTION	MODEL			
	FFMA4.5	FFMA6	FFMA9	FFMA12
CAPACITY(Kg)	4.5	6	9	12
FIRE RATING	21A 89B	21A 144B	21A 144B	21A 144B
DIAMETER(mm)	275	275	360	420
HEIGHT (mm)	210	210	210	225
DISCHARGE RANGE (Mtr)	8	8	9	9
DISCHARGE TIME (Sec)	12-14	16	18	21
CYLINDER WALL THICKNESS (mm)	1.8	1.8	2	2
CLASS OF FIRE	A B C & E			
EXTINGUISHING AGENT	FM-200 GAS			
OPERATING PRESSURE (Bar)	15			
TEST PRESSURE (Bar)	30			
OPERATING TEMPERATURE	68°C			
CYLINDER MATERIAL	COLD ROLLED STEEL			
PRINTING	CLEAR ATTRACTIVE SILK SCREEN PRINTING			
MOUNTING	CEILING MOUNTING			
EXPellant AGENT	NITROGEN			



Falcon Gold
YOU ARE SAFE WITH US



Standard Portable Foam Fire Extinguishers

Description

Foam Extinguishers are made of high quality ST14 by means of deep drawing.

Foam Fire Extinguishers are effective on class A & B fire.

Corrosive and impact resistant polyester paint finish (powder coating).

All Extinguishers are coated internally for optimal protection against rust and corrosion.

AFFF is an extinguishing agent which seals the burning surface against ignition.

The valve provided with safety release valve to release the excess pressure.

These extinguishers are manufactured according to international Standards and approved by local civil defence in U.A.E.

Cylinders of different capacity can be supplied upon request.

Foam Fire Extinguishers are available in cream color also.



Specification

Model	FF6L	FF9L	FF10L	FF12L
Capacity (Ltr)	6	9	10	12
Discharge Range (M)	5	6	6	7
Discharge Time (Sec)	≥28	≥30	≥32	≥35
Test Rating	13a 113b	21a 183b	27a 183b	34a 233b
Empty Weight (Kg)	2.5	3.55	3.55	3.98
Gross Weight (Kg)	8.5	12.55	13.55	15.98
Operating Pressure (Bar)	15			
Test Pressure (Bar)	30			
Extinguishing Agent	AFTT Foam			
Temperature Range	+5°C To +60°C			
Cylinder Material	Cold Rolled Steel Sheet			
Valve	Nickel Plated With Rigid Handle & Safety Valve Pin			
Painting	Electrostatic Polyester Epoxy Resin			
Class Of Fire	A B			
Carton Size (M3)	0.014	0.024	0.024	0.03

reserves the right to make changes at anytime without prior notice in Datsheet Ref No : FXD 043 Date of Issue : 13/06/2018 Ref No : 00



Falcon Gold
YOU ARE SAFE WITH US



Standard Portable Foam Fire Extinguishers

Description

Foam Extinguishers are made of high quality ST14 by means of deep drawing.

Foam Fire Extinguishers are effective on class A & B fire.

Corrosive and impact resistant polyester paint finish (powder coating).

All Extinguishers are coated internally for optimal protection against rust and corrosion.

AFFF is an extinguishing agent which seals the burning surface against ignition.

The valve provided with safety release valve to release the excess pressure.

These extinguishers are manufactured according to international Standards and approved by local civil defence in U.A.E.

Cylinders of different capacity can be supplied upon request.

Foam Fire Extinguishers are available in cream color also.

Specification

Model	FF6L	FF9L	FF10L	FF12L
Capacity (Ltr)	6	9	10	12
Discharge Range (M)	5	6	6	7
Discharge Time (Sec)	≥28	≥30	≥32	≥35
Test Rating	13a 113b	21a 183b	27a 183b	34a 233b
Empty Weight (Kg)	2.5	3.55	3.55	3.98
Gross Weight (Kg)	8.5	12.55	13.55	15.98
Operating Pressure (Bar)	15			
Test Pressure (Bar)	30			
Extinguishing Agent	AFTT Foam			
Temperature Range	+5°C To +60°C			
Cylinder Material	Cold Rolled Steel Sheet			
Valve	Nickle Plated With Rigid Handle & Safety Valve Pin			
Painting	Electrostatic Polyester Epoxy Resin			
Class Of Fire	A B			
Carton Size (M3)	0.014	0.024	0.024	0.03



reserves the right to make changes at anytime without prior notice in Datsheet Ref No : FXD 043 Date of Issue : 13/06/2018 Ref No : 00



Falcon Gold
YOU ARE SAFE WITH US



Standard Mobile Dry Powder Fire Extinguishers

Description

Steel cylinder of high quality ST14 and painted with anti-corrosive polyester paint (powder coating).

ABC dry chemical powder is effective on class A,B, C & E fires and it is ideal for multi-risk fire.

Corrosion and impact resistant polyester finish.

Equipped with entire brass valve with pistol system.

Ready for instant use and simple to operate.

Approved by UAE Civil Defence and it is manufactured according to International Standards.

The valve is equipped with safety release to avoid any bursting of cylinders during high temperature.

Do not use on fires involving carbon disulphate and flammable metal.

Available in Red and Blue colours.

Capacity of cylinder can be supplied upon request.

Specification

MODEL	FDP25	FDP50	FDP75	FDP100	FDP150	FDP25-OC	FDP50-OC
Capacity (Kg)	25	50	75	100	150	25	50
Discharge Range (M)	8	8	8	8	8	8	8
Discharge Time (Sec)	25	42	48	55	75	25	50
Total Height (Mm)	1120	1040	1150	1450	1200	1120	1040
Height Of Extg. (Mm)	815	920	1030	1300	1120	815	920
Diameter (Mm)	250	300	390	400	550	250	300
Hose Length (M)	3	5	5	5	5	3	5
Expellant Agent	Abc 70 % Dry Chemical Powder						
Operating Pressure (Bar)	15						
Test Pressure (Bar)	30						
Valve	Brass, Nickel Plated With Rigid Handle & Safety Valve Pin						
Wheel	Solid Rubber & Aluminium Alloy						
Rising Pipe	Plastic / Aluminium						
Cylinder Material	Cold Rolled Steel						
Temperature Range	Temperature Range						
Printing	Clear Attractive Screen Printing						
Class Of Fire	A B C & E						



reserves the right to make changes at anytime without prior notice in Datsheet Ref No : FXD 041-6 Date of Issue : 13/06/2018 Ref No : 00



Falcon Gold
YOU ARE SAFE WITH US



Mobile Carbon Dioxide Fire Extinguishers

Description

CO2 Fire Extinguishers are generally used for industrial fires.

Ideal agent for class B, C & E fires.

CO2 is electrically non-conductive and therefore safe for fighting fires in electrically powered equipment.

CO2 gas does not deteriorate with storage or freeze in container.

Purity of our CO2 gas reaches 99.98%

Valve is made from brass provided with safety release valve.

CO2 extinguishers are made of seamless carbon steel materials to withstand high storage pressure.

Snow horn with built-in nozzle specially designed to fit our valve to give the most efficient fire suppression.

After use, CO2 disperses without leaving any contamination or corrosive residue.

CO2 is colourless gas which reduces the oxygen of the air around the fire.

Approved by UAE Civil Defence.

Manufactured according to International Standards.

Available in black and red colour.

Other capacity of cylinders can be supplied upon request.



Specification

Model	FCD10	FCD20	FCD30	FCD45	FCD60
Capacity (Kg)	10	20	30	45	60
Discharge Time (Sec)	22	35	70	75	80
Discharge Range (M)	3	3	4	4	4
Hose length (M)	3	5	5	5	5
Class Of Fire	B, C & E				
Operating Pressure (Bar)	70 Bar				
Test Pressure (Bar)	250 Bar				
Temperature Range	-20°C +60°C				
Material	St52				
Valve	Brass Hot Stamping				
Paint Finish	Electrostatic Polyester Epoxy Resin				

reserves the right to make changes at anytime without prior notice in Datsheet Ref No : FXD 042-4 Date of Issue : 13/06/2018 Ref No : 00



أزيدك للمقاولات العامة
وأعمال الإلكتروميكانيكال
Azeidk for General Contracting & MEP Solutions

Saber Certificate.

AZEIDK



Falcon Gold

YOU ARE SAFE WITH US

C.R.4030244617

012 6880407/0581444606

info@azeidk.com

www.azeidk.com

المقر الرئيسي - جدة:

برج الصفا، مقابل عزيز مول، أعلى شركة عبداللطيف جميل، مبنى A، الدور الثالث، مكتب رقم ٣٤٠

الرياض:

حي الملز، شارع صلاح الدين، بجوار شركة زين، الدور الثاني، مكتب رقم ١٦.



شهادة مطابقة للمنتجات الخاضعة للوائح

Certificate of conformity for regulated products



We (.....Intertek International Ltd. Dubai Branch.....) office number (.....02615.....) are bearing full responsibility for the product described below is conforms to the conformity assessment procedure Conduct the relevant technical regulations and standards which mentioned during this certificate.

Certificate Number	19117-026-25-1792151	Issue Date	10/02/2025	Expire Date	10/02/2026
Certificate Type	Product Conformity Certificate (COC)	Commercial Registration No	4030267410 / 7012025560		
Establishment Address	5065 2 8073-22335 جدة				
Product and Manufacturer Data					
Model Name	FIRE EXTINGUISHERS		Trade Mark	Falcon Gold	
Product Name	FIRE EXTINGUISHERS				

Product
Description

FIRE EXTINGUISHERS




EN


 دليل الخدمة

 الخدمات


United Arab Emirates

دليل الخدمة 

Country of origin



 الخدمات

HS Code	842410290000
Technical Regulation	Technical Regulation for Fire Fighting Equipments and Materials
Manufacturer name	EMIRATES FIRE FIGHTING EQUIPMENT FACTORY L L C
Product test data	
Report number	
Report Date	
Decision of conformity assessment	Product Approved

<p>CB Organization Office Responsible Manager</p> <p>signature EN</p> <p>🔍</p> <p>🔔</p> <p>دليل الخدمة 💡</p>	<p>10/02/2025 04:52</p>	<p>CB Organization Office Stamp</p> <p>السaber</p> <p>الخدمات</p>
--	-------------------------	---


تفاصيل

تفاصيل أرقام الموديلات

عودة (ContactOfficer/MyRequests/HRRequests/)

أحكام وشروط (Home/Terms/) | تواصل معنا (home/ContactUs/) | بوابة الهيئة

(http://www.saso.gov.sa/ar/contactus/Pages/default.aspx) | سياسة الخصوصية (home/PrivacyPolicy/)



الهيئة السعودية للمواصفات والمقاييس والجودة (V 1.0.0.0) © 2025

https://raqmi.dga.gov.sa/platforms/platforms/16f0b27b-f131-4766-b3b3-)



(3d9d766c40e6/platform-license



أزيدك للمقاولات العامة
وأعمال الإلكتروميكانيكال
Azeidk for General Contracting & MEP Solutions

Previous Approvals

AZEIDK



Falcon Gold

YOU ARE SAFE WITH US

C.R.4030244617

012 6880407/0581444606

info@azeidk.com

www.azeidk.com

المقر الرئيسي - جدة:

برج الصفا، مقابل عزيز مول، أعلى شركة عبداللطيف جميل، مبنى A، الدور الثالث، مكتب رقم ٣٤٠.

الرياض:

حي الملز، شارع صلاح الدين، بجوار شركة زين، الدور الثاني، مكتب رقم ١٦.

PROJECT NAME: مشروع إنشاء مطبخ مركزي نموذجي بقصر الزاهر بجدة
LOCATION: قصر الزاهر - جدةPAGE
01 OF 01

DOCUMENT TRANSMITTAL/ SUBMITTAL

المستندات المقدمة

REF. NO.: 153

رقم:

SUBMITTAL NO:

MEC-MS-153R0

DATE: 14/07/2024

تاريخ:

☒ New Submittal☐ Re- Submittal

DISCIPLINE:

CIVIL ☐ARCHITECTURAL ☐STRUCTURAL ☐MECHANICAL ☒PLUMBING ☐ELECTRICAL ☐GENERAL ☐

ENCLOSURES (مرفقات)

Drawings

☐ مخططات

material submittal

☒ مواد

catalogs

☐ كتالوج

Request for inspection

☐ طلب استلام أعمالSpecification
مختبر☒ مواصفات

sample

☐ عينة

sketch

☐ سكتش

supplier

☐ مورد

lab

☐ معمل

test date

☐ بيانات اختبار

schedule

☐ جداول

report

☐ تقارير

clarification

☐ توضيحات

others

☐ أخرىDRWG. NO. مخطط رقم
SPECS. NO. رقم المواصفةرقم المراجعة
REV.

DESCRIPTION

عدد النسخ
NO. OF COPIES

0

FIRE EXTINGUISHERS – FALCON GOLD – EMARAT

1

ATTACHED: TECHNICAL DATA SHEET

ATTACHED: PREVIOUS APPROVALS

شركة المحترفون المتطورة

ANY REVIEW/APPROVAL FROM THE ENGINEER SHALL NOT RELIEVE THE CONTRACTOR OF HIS OBLIGATION TO PERFORM THE WORK IN ACCORDANCE WITH THE CONTRACT DOCUMENTS.

ITEM NO BOQ:

البند بجدول الكميات أو العقد:

LOCATION / USE

CO-ORDINATOR:

Name: AHMED SAMEH

Signature & Date:

REVIEWED BY:

Name: Ghadi Waznah

Signature & Date:

مكان الاستخدام: قصر الزاهر بجدة

مشروع المطبخ المركزي - قصر الزاهر

إدارة المشاريع

CONSULTANT REPRESENTATIVE APPROVAL & COMMENTS:

ملاحظات وتوصيات المهندس الاستشاري

- ضمان من إيمان شركة أزيد من 10 سنوات لخدمات الحريق من النوع (Falcon Gold) حسب المواصفات الفنية (FCOB و FCPB) -
- تقديم حجم واختيار الخدمة من النوع Automatic powder

NAME/SIGNATURE: Alwaleed Alshaleh

DATE/STAMP: 30/7/2024

ACTION CODES:

A) Approved (موافقة)

B) Approved As Noted (موافقة بملاحظات)

C) Revised And Re-Submit (تعديل وإعادة تقديم)

D) Rejected (مرفوض)

OWNER REPRESENTATIVE APPROVAL & COMMENTS:

مشروع: إنشاء مطبخ استشاري فندقي
(إجمالي 3 سنوات)

ACTION CODES:

A) Approved (موافقة)

B) Approved As Noted (موافقة بملاحظات)

C) Revised And Re-Submit (تعديل وإعادة تقديم)

D) Rejected (مرفوض)

NAME:

إعتماد المالك

الختم

Material Submittal



OWNER	: جمعية خيركم لتعليم القرآن الكريم وتحفيظه	Document No.	: MS-Mech-F.F-11
CONSULTANT	: الأبنية الحديثة	Date	: 06/07/2024
CONTRACTOR	: Azeidk Co. for Safety	Project No.	:
PROJECT	: فندق لحظات		
LOCATION	:		

Project	فندق لحظات	Submittal No.	MS-Mech-F.F-11	Ref. Spec's	
Ref. Dwg.		Date	6/07/2024		

Description:

Fire Extiguisher - Falcon Gold - U.A.E

☒ Catalogue ☐ Drawing ☐ Sample ☒ Certificate ☐ Others

Having Checked this submittal, we certify it conforms to the requirements
Of the contract Documents in all respects, except as otherwise indicated herein

Contractor: Azeidk Co. for Safety

Signature:

Date: 06/07/2024

ACTION

- ☐ Approved
☐ Approved As Noted
☒ Approved As Noted / Resubmittal Required
☐ Not Approved

Remarks/Comments

★ Installation as per NFPA requirements
★ ارجو تقديم شهادة CSA مع المنتج إذا وجد

Profession	Name	Signature	Review Date
Site Manager	محمد ابيدك		06/07/2024
Civil/Structural Engineer		<input type="checkbox"/> A APPROVED	
Electrical Engineer		<input type="checkbox"/> B APPROVED AS NOTED	
Mechanical Engineer		<input checked="" type="checkbox"/> C REVISE AND RESUBMIT	
		<input type="checkbox"/> D REJECTED	
		MB BUREAU REPRESENTATIVE	SIGNATURE DATE

CONTRACTOR	CONSULTANT	OWNER
 شركة وادي البنا للمقاولات العامة المحدودة Con Valley Co. LTD For General Contracting		

Material Submittal

Project:	Masdar Technical Services Project	Material Request No.:	CON-MR-MECH-
Client:	Al - Muhadib Group		
Consultant:	GAP Consultants Office		
Contractor:	Convalley For General Contracting		

DATE:- 7/11/2023

To be completed by the Contractor

Site: Type of Work: <div style="display: flex; align-items: center;"> <div style="margin-right: 10px;"> <input type="checkbox"/> Structural & Civil <input type="checkbox"/> Architecture <input checked="" type="checkbox"/> Mechanical <input type="checkbox"/> Electrical <input type="checkbox"/> Other </div> </div>	
Material Description :	FHC & FE

Specifications/ Drawing Ref. :

Tender Drawing & B.O.Q

B.O.Q. Ref.:

Enclosures :	<input checked="" type="checkbox"/> Catalogues	<input type="checkbox"/> Technical Data	<input type="checkbox"/> Literature	<input type="checkbox"/> Certificates
	<input type="checkbox"/> Samples	<input type="checkbox"/> Operational & Maintenance Manual	<input type="checkbox"/>	<input type="checkbox"/>

Manufacturer / Supplier: **AAEIDK (FALCON)**

Local Agent :

Additional relevant information :

FALCON FIRE HOSE CABINET (80*80*30 CM) RUBBER HOSE 1 "
FALCON CO2 FE 6 KG
FALCON POWDER FE6 KG

Checked By:

Signature:

Project Manager:

Signature:

To be completed by the Consultant :

Date Received : / /

☒ Approved
☐ Revise & Resubmit

Received By :

☒ AAN
☐ Not Approved

Comments :

Installation should be as per NFPA-14 and NFPA-10 for fire extinguishers.

Date : 07/11/2023

Checked by :

ENG HAMDY

Signature :

[Handwritten Signature]

Date received by the Contractor: / /

Received By :

Signature :

OWNER	CONSULTANT	CONTRACTOR
 هاند العالمية للفنادق والمنتجعات السياحية HAND INTERNATIONAL HOTELS & RESORTS	 تصميم - إشراف - إدارة مشاريع	 شركة أزيدك للخدمات الهندسية

PROJECT NAME: Platinum Park

LOCATION: Taif

MATERIAL SUBMITTAL / APPROVAL SHEET

<input checked="" type="checkbox"/> NEW SUBMITTAL	<input type="checkbox"/> RE-SUBMITTAL	SUBMITTAL DATE: 18/03/2023	SUBMITTAL NO.: MS-Mech-FF-03	REV.: 00
PURPOSE OF SUBMITTAL				
<input checked="" type="checkbox"/> FOR APPROVAL	<input type="checkbox"/> FOR COMMENTS	<input type="checkbox"/> FOR INFORMATION		
DISCIPLINE:				
<input checked="" type="checkbox"/> MECHANICAL	<input checked="" type="checkbox"/> Firefighting	<input type="checkbox"/> CIVIL	<input type="checkbox"/> ELECTRICAL	
<input type="checkbox"/> H. V. A. C.	<input type="checkbox"/> PLUMBING	<input type="checkbox"/> OTHERS...	Specify: Fire Fighting	

MATERIAL NAME:	Fire Extinguishers	ORIGIN:	Emirate
BOQ. REFERENCE:		MANUFACTURER/SUPPLIER:	Falcon Gold
SPECS. REF.:		SUPPLIER:	
DRAWING REF.:		MATERIAL DELIVERY PERIOD:	Stock
LOCATION:	Taif	MATERIAL REQUIRED AT SITE:	
QUANTITY:		SAMPLE ATTACHMENT:	
B. S. REFERENCE:		CERTIFICATE ATTACHMENT:	




WARRANTY FROM THE MANUFACTURER / SUPPLIER:

CONTRACTORS REMARKS (if any):

CONSULTANTS COMMENTS:

* Follow NFPA-14 in installation heights

CONTRACTOR		CONSULTANT	
NAME:	Mohamed Rabea	NAME:	
POSITION:	Mechanical Engineer	POSITION:	Consultant Engineer
SIGNATURE:		SIGNATURE:	
DATE:	12/03/2023	DATE:	
APPROVAL STATUS:			
<input checked="" type="checkbox"/> MATERIAL APPROVED		<input checked="" type="checkbox"/> APPROVED WITH COMMENTS	
<input type="checkbox"/> MATERIAL REJECTED			
RECEIVED BY:	SIGNATURE:	RECEIVED BY:	SIGNATURE:
(CONSULTANT)	DATE: March 22nd 2023	(CONTRACTOR)	DATE:

OWNER		CONSULTANT		CONTRACTOR	
					
PROJECT NAME: Rusd Towers				LOCATION: JEDDAH	
MATERIAL SUBMITTAL / APPROVAL SHEET					
<input checked="" type="checkbox"/> NEW SUBMITTAL		<input type="checkbox"/> RE-SUBMITTAL		SUBMITTAL DATE: 20/02/2023	
				SUBMITTAL NO.: MS-Mech-03	
				REV.: 00	
PURPOSE OF SUBMITTAL		<input checked="" type="checkbox"/> FOR APPROVAL		<input type="checkbox"/> FOR COMMENTS	
				<input type="checkbox"/> FOR INFORMATION	
DISCIPLINE:		<input checked="" type="checkbox"/> MECHANICAL		<input checked="" type="checkbox"/> Firefighting	
		<input type="checkbox"/> H. V. A. C.		<input type="checkbox"/> CIVIL	
		<input type="checkbox"/> PLUMBING		<input type="checkbox"/> ELECTRICAL	
				<input type="checkbox"/> OTHERS...	
				Specify: Firefighting	
MATERIAL NAME:	Fire Extinguishers		ORIGIN:		
BOQ. REFERENCE:			MANUFACTURER/SUPPLIER:	Falcon Gold	
SPECS. REF.:			SUPPLIER:		
DRAWING REF.:			MATERIAL DELIVERY PERIOD:	Stock	
LOCATION:	JEDDAH		MATERIAL REQUIRED AT SITE:	Rusd Towers	
QUANTITY:			SAMPLE ATTACHMENT:		
B. S. REFERENCE:			CERTIFICATE ATTACHMENT:		
WARRANTY FROM THE MANUFACTURER / SUPPLIER:					
CONTRACTORS REMARKS (if any):					
CONSULTANTS COMMENTS:					
Installation must be according to NFPA requirements.					
CONTRACTOR			CONSULTANT		
NAME: Mohamed Rabea			NAME: Mohamed Akar		
POSITION: Mechanical Engineer			POSITION: Consultant Engineer		
SIGNATURE:			SIGNATURE:		
DATE: 20/02/2023			DATE: 26/02/2023		
APPROVAL STATUS:			<input checked="" type="checkbox"/> MATERIAL APPROVED		
			<input checked="" type="checkbox"/> APPROVED WITH COMMENTS		
			<input type="checkbox"/> MATERIAL REJECTED		
RECEIVED BY: SIGNATURE:			RECEIVED BY: SIGNATURE:		
(CONSULTANT) DATE: 26/02/2023			(CONTRACTOR) DATE:		



أزيدك للمقاولات العامة
وأعمال الإلكتروميكانيكال
Azeidk for General Contracting & MEP Solutions

Authorization Letter.

AZEIDK



Falcon Gold

YOU ARE SAFE WITH US

C.R.4030244617

012 6880407/0581444606

info@azeidk.com

www.azeidk.com

المقر الرئيسي - جدة:

برج الصفا، مقابل عزيز مول، أعلى شركة عبداللطيف جميل، مبنى A، الدور الثالث، مكتب رقم ٣٤٠.

الرياض:

حي الملز، شارع صلاح الدين، بجوار شركة زين، الدور الثاني، مكتب رقم ١٦.

CERTIFICATE OF AUTHORIZED DISTRIBUTOR



Falcon Gold, the prestigious Emirati company,
proudly announces the appointment of Azeidk Group in KSA & EGYPT
as an authorized distributor of its products.
With this certificate, Azeidk is recognized as an authorized distributor for
all Falcon Gold products within the Kingdom of Saudi Arabia & EGYPT.

Azeidk was selected for its excellence and expertise in the field of security
& safety, and we have full confidence in its ability to
provide high-quality and reliable services to its clients in KSA & EGYPT.

This certificate is effective from the date of issuance & remains valid
until MAY 2025.

We wish Azeidk success and progress as an authorized distributor of
our products, and we look forward to building a strong
& fruitful partnership with them.

2024-5

DATE

GENERAL MANAGER





**Exclusive Appointment of Azeidk as the Sole Agent
for Falcon Gold Products in Saudi Arabia and Egypt**

To: Azeidk

We at **Falcon Gold** are pleased to announce the appointment of **Azeidk** as the exclusive distributor of our products in both **Saudi Arabia** and **Egypt**.

This decision reflects our full confidence in Azeidk's ability to deliver our products and services with the highest quality and professionalism, meeting the expectations of our clients and adhering to the highest safety standards.

Through this partnership, Azeidk will take on the responsibility of distributing and promoting all **Falcon Gold** products in the Saudi and Egyptian markets, including our wide range of fire protection solutions such as **cabinets, hoses, extinguishers, valves**, and more. These products are certified to the highest international standards, including **NFPA, UL, and Kitemark**.

At **Falcon Gold**, we are confident that Azeidk, with its vast experience and outstanding team, will be the ideal partner to strengthen our presence in these key markets. Together, we will work to ensure that our clients' needs are met with the utmost quality and safety.

This exclusive distributorship is valid from the date of issuance and will remain in effect until **2030**, with the possibility of renewal based on our mutual achievements.

We wish **Azeidk** continued success and growth in this important partnership, and we look forward to a bright and prosperous future together.

Sincerely,
Falcon Gold



Falcon Gold
YOU ARE SAFE WITH US



+971 524312926
+971 43340813



info@falcon-gold.com
www.falcon-gold.com



Sheikh Zayed Rd-Al Wasl
Building-first floor office
Number 128 Dubai



أزيدك للمقاولات العامة
وأعمال الإلكتروميكانيكال
Azeidk for General Contracting & MEP Solutions

Azeidk Co. Documents



Falcon Gold

YOU ARE SAFE WITH US

C.R.4030244617

012 6880407/0581444606

info@azeidk.com

www.azeidk.com

المقر الرئيسي - جدة:

برج الصفا، مقابل عزيز مول، أعلى شركة عبداللطيف جميل، مبنى A، الدور الثالث، مكتب رقم ٣٤٠

الرياض:

حي الملز، شارع صلاح الدين، بجوار شركة زين، الدور الثاني، مكتب رقم ١٦.

وثيقة التأهيل

رقم الوثيقة: ٢٤٥٣٦٢١١٦٢٥

تاريخ إصدار الوثيقة	٢٠٢٤/١٠/٢١ م	تاريخ إنتهاء الوثيقة	٢٠٢٥/١٠/٢١ م
الاسم التجاري	شركة ازيدك للمقاولات العامه		
رقم السجل التجاري	٤٠٣٠٢٤٤٦١٧	موقعها الرئيسي	جدة
النشاط المرخص	مقاولات الوقاية والحماية من الحريق		
الفئة	مقاولات الوقاية والحماية من الحريق		

تصادق وترخص الهيئة العليا للأمن الصناعي لهذه المنشأة لمزاولة النشاط المذكور في هذه الوثيقة.

* هذه الوثيقة سارية للسجل التجاري الرئيسي وجميع السجلات التجارية الفرعية للمنشأة.



رخصة مزاولة نشاط

رقم الرخصة: ٢٣٥١٠٠٧٧٣٣٢

شركة ازيدك للمقاولات العامه				الإسم التجاري	
٧٠١٤١٢٦٢٦٧		الرقم الموحد للمنشآت (٧)	٤٠٣٠٢٤٤٦١٧	رقم السجل التجاري	
جدة	منطقة مزاولة النشاط	١٤٤٧-٠٦-٢٦	تاريخ الإنتهاء	١٤٤٤-٠٦-٢٦	تاريخ الإصدار
البيع بالجملة لأجهزة ومعدات ومواد الوقاية والحماية من الحريق				النشاط المرخص	
				الأجهزة والمعدات	

تشهد الهيئة العليا للأمن الصناعي بأن المنشأة الموضحة أعلاه قد أستوفت كافة الإجراءات والإشتراطات النظامية لمزاولة النشاط الموضح أعلاه وقد أصدرت لها هذه الرخصة كمنشأة مصرح لها لمزاولة النشاط المذكور.



* للتحقق من صلاحية الرخصة الرجاء الدخول على منصة الهيئة العليا للأمن الصناعي <https://hcis.gov.sa>
* يتطلب وجود النشاط في السجل التجاري المذكور أعلاه، على أن يكون السجل التجاري ساري المفعول

رخصة مزاولة نشاط

رقم الرخصة: ٢٣٥١٠٠٧٧٣٣٢

شركة ازيدك للمقاولات العامه				الإسم التجاري	
٧٠١٤١٢٦٢٦٧		الرقم الموحد للمنشآت (٧)	٤٠٣٠٢٤٤٦١٧	رقم السجل التجاري	
جدة	منطقة مزاولة النشاط	١٤٤٧-٠٦-٢٦	تاريخ الإنتهاء	١٤٤٤-٠٦-٢٦	تاريخ الإصدار
البيع بالجملة لأجهزة ومعدات ومواد الوقاية والحماية من الحريق				النشاط المرخص	
				الأجهزة والمعدات	

تشهد الهيئة العليا للأمن الصناعي بأن المنشأة الموضحة أعلاه قد أستوفت كافة الإجراءات والإشتراطات النظامية لمزاولة النشاط الموضح أعلاه وقد أصدرت لها هذه الرخصة كمنشأة مصرح لها لمزاولة النشاط المذكور.



* للتحقق من صلاحية الرخصة الرجاء الدخول على منصة الهيئة العليا للأمن الصناعي <https://hcis.gov.sa>
* يتطلب وجود النشاط في السجل التجاري المذكور أعلاه، على أن يكون السجل التجاري ساري المفعول

رخصة مزاولة نشاط

رقم الرخصة: ٢٣٥١٣١٠١٦٣٢

شركة ازيدك لاجهزة السلامة			الإسم التجاري
٧٠٣١٢٩٩٨٦٥	الرقم الموحد للمنشآت (٧)	٤٠٣٢٢٦٣١٤١	رقم السجل التجاري
١٤٤٨-٠٥-٢٧	تاريخ الإنتهاء	١٤٤٥-٠٥-٢٧	تاريخ الإصدار
الطائف	منطقة مزاولة النشاط	البيع بالتجزئة لمعدات الإطفاء والإنقاذ	
			الأجهزة والمعدات

تشهد الهيئة العليا للأمن الصناعي بأن المنشأة الموضحة أعلاه قد أستوفت كافة الإجراءات والإشترطات النظامية لمزاولة النشاط الموضح أعلاه وقد أصدرت لها هذه الرخصة كمنشأة مصرح لها لمزاولة النشاط المذكور.



* للتحقق من صلاحية الرخصة الرجاء الدخول على منصة الهيئة العليا للأمن الصناعي <https://hcis.gov.sa>
* يتطلب وجود النشاط في السجل التجاري المذكور أعلاه، على أن يكون السجل التجاري ساري المفعول



رخصة مزاولة نشاط

رقم الرخصة: ٢٣٠٢١٠٧٩٣٦٧

الإسم التجاري			شركة أزيدك لأجهزة السلامة		
رقم السجل التجاري			٤٠٣٠٢٦٧٤١٠		
رقم الموحّد للمنشآت (٧)			٧٠١٢٠٢٥٥٦٠		
تاريخ الإصدار			١٤٤٤-٠٨-٠٦		
تاريخ الإنتهاء			١٤٤٧-٠٨-٠٦		
النشاط المرخص			تركيب وصيانة أجهزة ومعدات الإطفاء		
الأجهزة والمعدات			منطقة مزاولة النشاط		
			جدة		

تشهد إدارة التراخيص الأمنية المركزية بأن المنشأة الموضحة أعلاه قد أستوفت كافة الإجراءات والإشترطات النظامية لمزاولة النشاط الموضح أعلاه وقد أصدرت لها هذه الرخصة كمنشأة مصرح لها لمزاولة النشاط المذكور.

أمين عام الهيئة العليا للأمن الصناعي

عقيد مهندس / عدل بن زايد العتيبي



* للتحقق من صلاحية الرخصة الرجاء الدخول على منصة الهيئة العليا للأمن الصناعي <https://hcis.gov.sa>
* يتطلب وجود النشاط في السجل التجاري المذكور أعلاه، على أن يكون السجل التجاري ساري المفعول





رخصة مزاولة نشاط

رقم الرخصة: ٢٣٠٢٢٠٧٨٤٤٥

الإسم التجاري				شركة أزيدك لأجهزة السلامة	
رقم السجل التجاري				٤٠٣٠٢٦٧٤١٠	الرقم الموحد للمنشآت (٧)
تاريخ الإصدار				١٤٤٤-٠٧-١١	تاريخ الإنتهاء
النشاط المرخص				تركيب وصيانة أجهزة ومعدات الإنذار من الحريق	
الأجهزة والمعدات					

تشهد إدارة التراخيص الأمنية المركزية بأن المنشأة الموضحة أعلاه قد أستوفت كافة الإجراءات والإشترطات النظامية لمزاولة النشاط الموضح أعلاه وقد أصدرت لها هذه الرخصة كمنشأة مصرح لها لمزاولة النشاط المذكور.

أمين عام الهيئة العليا للأمن الصناعي

عقيد مهندس / عدل بن زايد العتيبي



* للتحقق من صلاحية الرخصة الرجاء الدخول على منصة الهيئة العليا للأمن الصناعي <https://hcis.gov.sa>
* يتطلب وجود النشاط في السجل التجاري المذكور أعلاه، على أن يكون السجل التجاري ساري المفعول





رخصة مزاولة نشاط

رقم الرخصة: ٢٣٥١٠٠٧٧٣٣٢

شركة أزيك لأجهزة السلامة				الإسم التجاري
٧٠١٢٠٢٥٥٦٠		الرقم الموحد للمنشآت (٧)	٤٠٣٠٢٦٧٤١٠	رقم السجل التجاري
جدة	منطقة مزاولة النشاط	١٤٤٧-٠٦-٢٦	تاريخ الإنتهاء	١٤٤٤-٠٦-٢٦
البيع بالجملة لأجهزة ومعدات ومواد الوقاية والحماية من الحريق				النشاط المرخص
				الأجهزة والمعدات

تشهد إدارة التراخيص الأمنية المركزية بأن المنشأة الموضحة أعلاه قد أستوفت كافة الإجراءات والإشترطات النظامية لمزاولة النشاط الموضح أعلاه وقد أصدرت لها هذه الرخصة كمنشأة مصرح لها لمزاولة النشاط المذكور.

أمين عام الهيئة العليا للأمن الصناعي

عقيد مهندس / عادل بن زايد العتيبي



* للتحقق من صلاحية الرخصة الرجاء الدخول على منصة الهيئة العليا للأمن الصناعي <https://hcis.gov.sa>
* يتطلب وجود النشاط في السجل التجاري المذكور أعلاه، على أن يكون السجل التجاري ساري المفعول



رقم الرخصة: ٢٤٥٠٦١١٧٢٣

شركة أريدك لاجهزة السلامة				الإسم التجاري
٧٠٣٨٨٧٧١٤٣				رقم السجل التجاري
١٤٤٨-١٠-٢٨				تاريخ الإصدار
١٤٤٥-١٠-٢٨				تاريخ الانتهاء
منطقة مزاولة النشاط				جدة
تركيب وصيانة الأجهزة الأمنية				النشاط المرخص
كاميرات المراقبة الأمنية، أنظمة الدوائر التلفزيونية المغلقة، أجهزة وأنظمة الإنذار ضد السرقة، أجهزة وبوابات الكشف عن المعادن، أجهزة تفتيش الحقائق والطرود، أجهزة بوابات الدخول والخروج بالبطاقات الممغنطة والبصمة، السياج الأمني				الأجهزة والمعدات

تشهد الهيئة العليا للأمن الصناعي بأن المنشأة الموضحة أعلاه قد أستموت كافة الإجراءات والإشتراطات النظامية لمزاولة النشاط الموضح أعلاه وقد أصدرت لها هذه الرخصة كمنشأة مصرح لها لمزاولة النشاط المذكور.



* للتحقق من صلاحية الرخصة الرجاء الدخول على منصة الهيئة العليا للأمن الصناعي <https://hcis.gov.sa>

* يتطلب وجود النشاط في السجل التجاري المذكور أعلاه، على أن يكون السجل التجاري ساري المفعول

رخصة مزاولة نشاط

رقم الرخصة: ٢٣٥١٣١٠١٦٣٢

شركة ازيدك لاجهزة السلامة			الإسم التجاري	
٧٠٣١٢٩٩٨٦٥			٤٠٣٢٢٦٣١٤١	رقم السجل التجاري
١٤٤٨-٠٥-٢٧			١٤٤٥-٠٥-٢٧	تاريخ الإصدار
منطقة مزاولة النشاط			تاريخ الإنتهاء	النشاط المرخص
الطائف			البيع بالتجزئة لمعدات الإطفاء والإنقاذ	الأجهزة والمعدات

تشهد الهيئة العليا للأمن الصناعي بأن المنشأة الموضحة أعلاه قد أستوفت كافة الإجراءات والإشترطات النظامية لمزاولة النشاط الموضح أعلاه وقد أصدرت لها هذه الرخصة كمنشأة مصرح لها لمزاولة النشاط المذكور.



* للتحقق من صلاحية الرخصة الرجاء الدخول على منصة الهيئة العليا للأمن الصناعي <https://hcis.gov.sa>
* يتطلب وجود النشاط في السجل التجاري المذكور أعلاه، على أن يكون السجل التجاري ساري المفعول

رخصة مزاولة نشاط

رقم الرخصة: ٢٣٠٢٢١٠٢٠٠٣

شركة ازيدك لاجهزة السلامة			الإسم التجاري	
٧٠٣١٢٩٩٨٦٥			٤٠٣٢٢٦٣١٤١	رقم السجل التجاري
١٤٤٨-٠٦-٠١			١٤٤٥-٠٦-٠١	تاريخ الإصدار
منطقة مزاولة النشاط			تاريخ الإنتهاء	النشاط المرخص
الطائف			تركيب وصيانة أجهزة ومعدات الإنذار من الحريق	الأجهزة والمعدات

تشهد الهيئة العليا للأمن الصناعي بأن المنشأة الموضحة أعلاه قد أستوفت كافة الإجراءات والإشتراطات النظامية لمزاولة النشاط الموضح أعلاه وقد أصدرت لها هذه الرخصة كمنشأة مصرح لها لمزاولة النشاط المذكور.



* للتحقق من صلاحية الرخصة الرجاء الدخول على منصة الهيئة العليا للأمن الصناعي <https://hcis.gov.sa>
* يتطلب وجود النشاط في السجل التجاري المذكور أعلاه، على أن يكون السجل التجاري ساري المفعول



رخصة مزاولة نشاط

رقم الرخصة: ٨٢٧٠٨٠١١٠٣٥١١

شركة أزيك لأجهزة السلامة				الإسم التجاري
٧٠٣٣٨١٠٣٦٢	الرقم الموحد للمنشآت (٧)	٢٠٥٠١٦٨٠٢٥	رقم السجل التجاري	
١٤٤٧-٠٩-٢٠	تاريخ الإنتهاء	١٤٤٤-٠٩-٢٠	تاريخ الإصدار	
الدمام	منطقة مزاولة النشاط		النشاط المرخص	البيع بالتجزئة لأجهزة ومعدات ومواد الوقاية والحماية من الحريق
			الأجهزة والمعدات	

تشهد إدارة التراخيص الأمنية المركزية بأن المنشأة الموضحة أعلاه قد أستوفت كافة الإجراءات والإشترطات النظامية لمزاولة النشاط الموضح أعلاه وقد أصدرت لها هذه الرخصة كمنشأة مصرح لها لمزاولة النشاط المذكور.

أمين عام الهيئة العليا للأمن الصناعي

عقيد مهندس / عدل بن زايد العتيبي



* للتحقق من صلاحية الرخصة الرجاء الدخول على منصة الهيئة العليا للأمن الصناعي <https://hcis.gov.sa>
* يتطلب وجود النشاط في السجل التجاري المذكور أعلاه، على أن يكون السجل التجاري ساري المفعول



اعتماد*

شهادة اعتماد

تصنيف مقدمي خدمات المدن

تُمنح وزارة الشؤون البلدية والقروية والإسكان شهادة الاعتماد*

للمنشأة

مؤسسة از يدك للمقاولات العامة

في قطاع التشييد والبناء



4030244617

السجل التجاري

الإنشاءات العامة للمباني السكنية، الإنشاءات العامة للمباني الغير السكنية ، يشمل، (المدارس ، المستشفيات، الفنادق ...الخ) الإنشاءات العامة للمباني الحكومية، ترميمات المباني السكنية والغير سكنية

النشاط

- يسري مفعول هذه الشهادة حتى تاريخ 04/10/1444 هـ / الموافق 25/04/2023 م
- تصدر هذه الشهادة إلكترونياً وعلى الجهات المالكة للمشاريع التحقق من الشهادة المقدمة من خلال موقع الوزارة




وكيل الوزارة لتصنيف المقاولين
د. أحمد بن جميل قطان

تصنيف
مقدمي خدمات المدن



* هذه الشهادة منحت بغرض اصدار وثيقة التأمين ضد العيوب الخفية و الدخول في المنافسات الحكومية الأقل من قيمة مشاريع الدرجة الخامسة.



شهادة

تصنيف مقدمي خدمات المدن

تمنح وزارة الشؤون البلدية والقروية والإسكان شهادة تصنيف بالدرجة

للمنشأة شركة ازيدك للمقاولات العامة



بيانات المنشأة	الرقم الوطني الموحد/ الترخيص	تاريخ إصدار السجل التجاري/ الترخيص	اسم مالك المنشأة	نوع المنشأة	جنسية المنشأة	رأس المال
	7014126267	15/04/2013	غازي جابر درويش القحطاني	ذات مسؤولية محدودة	سعودي	100000.0
بيانات شهادة التصنيف	رقم الشهادة	تاريخ الإصدار	درجة التقييم الائتماني	درجة التقييم الفني		
	2024005747	29/05/2024	BBB+	88.55		
أنشطة شهادة التصنيف	المجال	الأنشطة				
	التشييد والبناء	الإنشاءات العامة للمباني السكنية، الإنشاءات العامة للمباني الغير السكنية، يشمل (المدارس، المستشفيات، الفنادق... الخ) الإنشاءات العامة للمباني الحكومية، ترميمات المباني السكنية والغير سكنية				

وكيل الوزارة لتنظيم مشغلي المدن

عبدالرحمن بن أحمد الغرني

- يسري مفعول هذه الشهادة حتى تاريخ 29/05/2026

- تصدر هذه الشهادة إلكترونياً وعلى الجهات المالكة للمشاريع التحقق من الشهادة المقدمة من خلال موقع الوزارة.

